

Project Name: _____
 Location: _____
 Engineer: _____
 Submitted to: _____
 Submitted by: _____
 Reference: _____

Approval: _____
 Date: _____
 Construction: _____
 Unit #: _____
 Drawing #: _____

Performance

<i>Indoor Unit Model No:</i>	FXNQ18MVJU9
<i>Rated Cooling Capacity (Btu/hr):</i>	18000
<i>Sensible Capacity (Btu/hr):</i>	12200
<i>Cooling Input Power (kW):</i>	0.105
<i>Rated Heating Capacity (Btu/hr):</i>	20000
<i>Heating Input Power (kW):</i>	0.105

<i>Indoor Unit Type:</i>	Floor Standing (Concealed)
<i>Rated Cooling Conditions</i>	Indoor: 80°F DB/67°F WB Ambient: 95°F DB/75°F WB
<i>Rated Heating Conditions</i>	Indoor: 70°F DB/60°F WB Ambient: 47°F DB/43°F WB
<i>Rated Piping Length (ft)</i>	25
<i>Rated Height Separation (ft)</i>	0

Indoor Unit Details

<i>Power Supply (V/Hz/Ph):</i>	208-230/60/1ph
<i>Power Supply Connections:</i>	L1, L2, Ground
<i>Min. Circuit Amps MCA (A):</i>	0.6
<i>Max. Overcurrent Protection (MOP) (A):</i>	15
<i>Dimensions (HxWxD):</i>	24x53-1/8x8-5/8
<i>Panel (HxWxD):</i>	N/A
<i>Net Weight (lbs):</i>	60
<i>Net Weight with Panel (lbs):</i>	

<i>Airflow Rate (CFM wet coil)</i>	490//380
<i>Moisture Removal (pt/h):</i>	
<i>Gas Pipe Connection (inch):</i>	1/2
<i>Liquid Pipe Connection (inch):</i>	1/4
<i>Condensate Connection (inch):</i>	53/64
<i>Sound Pressure Level (dBA):</i>	40
<i>Sound Power Level (dBA):</i>	
<i>External Static Pressure/Max (inWg):</i>	0 / 0
<i>Controller Name:</i>	

FXNQ18MVJU9



FXNQ18MVJU9

Std U.S. Warranty: 7yrs Compressor, 1yrs Parts

Project Name: _____
 Location: _____
 Engineer: _____
 Submitted to: _____
 Submitted by: _____
 Reference: _____

Approval: _____
 Date: _____
 Construction: _____
 Unit #: _____
 Drawing #: _____

Dimensional Drawing - Indoor Unit

FXNQ18MVJU9

